Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Cope Hall

Date/Time of Inspection: 01/04/2013

Fire Extinguisher Number	Date of Last Inspection	Comments
1-3	12-12	
1-4	12-12	
1-5	12-12	
1-7	12-12	
1-9	12-12	
P-1 Pool	12-12	
B-1 Men's Locker room	12-12	
B-2 Women's locker room	12-12	

James Keith 01/04/2013

Fire Compliance Officer/Asst Patrol Officer — Date 1-4-13

Chief of Police — Date 1-4-13

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: February 4, 2013 0900 hrs.

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance		OK
1-2 at gym 1st door	"	OK
1-3 near rm 126	"	OK
1-4 near 2nd gym dr	"	OK
1-5 rear exit	"	OK
1-7 near rm 130		OK
1-8 inside gym	"	OK
1-9 near rm 122	"	OK
B-1 visitors locker	"	OK
B-2 training rm	"	OK
B-3 men's locker	"	OK

P/O Johnson

Officer Johnson
Fire Compliance Officer/Asst Patrol Officer

2-4-13
Date

Chief of Police

3-11-13
Date

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: March 8, 2013 1400 hrs

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance		OK
1-2 at gym 1st door	"	OK
1-3 near rm 126	"	OK
1-4 near 2nd gym dr	"	OK
1-5 rear exit	"	OK
1-7 near rm 130		Recharge
1-8 inside gym	"	OK
1-9 near rm 122	"	OK
B-1 visitors locker	"	OK
B-2 training rm	"	OK
B-3 men's locker	"	OK

P/O Richardson/Miles

Dolores Richardson

Fire Compliance Officer/Asst Patrol Officer

3·8·13

Date

Lawrence W Richards

Chief of Police

3-8-13

Date

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: April 11, 2013 0900 hrs.

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance	3-8-13	OK
1-2 at gym 1st door	"	OK
1-3 near rm 126	"	OK
1-4 near 2nd gym dr	"	OK
1-5 rear exit	"	OK
1-7 near rm 130	"	OK
1-8 inside gym	"	Recharge
1-9 near rm 122	"	OK
B-1 visitors locker	"	Tag required
B-2 training rm	"	OK
B-3 men's locker	"	OK

P/O Richardson/ Miles

Dolores Richardson

Fire Compliance Officer/Asst Patrol Officer

4·11·13

Date

Lawrence W Richards

Chief of Police

4-11-13

Date

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: May 15, 2013 1140 hrs

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance	4-11-13	OK
1-2 at gym 1st door	"	OK
1-3 near rm 126	"	OK
1-4 near 2nd gym dr	"	OK
1-5 rear exit	"	OK
1-7 near rm 130	"	OK
1-8 inside gym	"	Recharge
1-9 near rm 122	"	OK
B-1 visitors locker	"	Tag required
B-2 training rm	"	OK
B-3 men's locker	"	OK

P/O Richardson/ Miles

Fire Compliance Officer/Asst Patrol Officer — 5-15-13 Date

Lawrence W Richards

Chief of Police — 5-15-13 Date

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: June 11, 2013 1215hrs

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance	5-15-13	OK
1-2 at gym 1st door	5-15-13	OK
1-3 near rm 126	5-15-13	OK
1-4 near 2nd gym dr	5-15-13	OK
1-5 rear exit	5-15-13	OK
1-7 near rm 130	5-15-13	OK
1-8 inside gym	5-15-13	Recharge
1-9 near rm 122	5-15-13	OK
B-1 visitors locker	5-15-13	Tag required
B-2 training rm	5-15-13	OK
B-3 men's locker	5-15-13	OK

P/O Richardson/ Miles

Paul Miles — 6-11-13

Fire Compliance Officer/Asst Patrol Officer — Date

[illegible signature] — 7-8-13

Chief of Police — Date

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL 3·8

Date /Time of inspection: ~~February 4, 2013 0900 hrs.~~ 7·29.2013 21:50 –

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance	6.11.13	OK [redacted] 77
1-2 at gym 1st door	5.15.13 "	OK [redacted] 77
1-3 near rm 126	6.11.13 "	OK [redacted] 77
1-4 near 2nd gym dr	6.11.13 "	OK [redacted] 77
1-5 rear exit	6.11.13 "	OK [redacted] 77
1-7 near rm 130	6.11.13	OK [redacted] 77
1-8 inside gym	[redacted] 5.15.13	need charged [redacted] 77
1-9 near rm 122	6.11.13 "	OK [redacted] 77
B-1 visitors locker	[redacted] 6.11.13	need Tag [redacted] OK 77
B-2 training rm	6.11.13 "	OK [redacted] 77
B-3 men's locker	6.11.13 " need Tag	OK [redacted] 77

~~P/O Johnson~~ C.Wilson

Fire Compliance Officer/Asst Patrol Officer — Date: 7-29-13

Chief of Police — Date: 9-4-13

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: 8/27/13 1400

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance	7.29.13	OK
1-2 at gym 1st door	7.29.13	OK
1-3 near rm 126	7.29.13	OK
1-4 near 2nd gym dr	7.29.13	OK
1-5 rear exit	7.29.13	OK
1-7 near rm 130	7.29.13	OK
1-8 inside gym	7.29.13	needs charged
1-9 near rm 122	7.29.13	OK
B-1 visitors locker	7.29.13	OK
B-2 training rm	7.29.13	OK
B-3 men's locker	7.29.13	OK

C. Wood #77
Fire Compliance Officer/Asst Patrol Officer

8/27/13
Date

Lawrence W. Richards
Chief of Police

9/16/13
Date

Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: COPE HALL

Date /Time of inspection: 9-30-13 1245 hrs

Date/Time of Inspection: Extinguisher Number	Date of Last Inspection	Comments
1-1 at entrance	8-27-13	OK
1-2 at gym 1st door	8-27-13	OK
1-3 near rm 126	8-28-13	OK
1-4 near 2nd gym dr	8-28-13	OK
1-5 rear exit	8-28-13	OK
ROOM 138 1-7 near rm 138	8-28-13	OK
1-8 inside gym		
1-9 near rm 122	8/28/13	OK
B-1 visitors locker	7-29-13	OK Needs New TAG
B-2 training rm	8-28-13	OK Need New TAG
B-3 men's locker	8-12-13	OK Need New TAG

Fire Compliance Officer/Asst Patrol Officer — Date: 9-30-13

Chief of Police (Lawrence W. Richards) — Date: 9/30/13