



Cheyney State University of Pennsylvania
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: January 3, 2013 1150 hrs.

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	12-6-12	OK
1-2 near stair #1	12-6-12	OK
1-3 near exit door	12-6-12	OK
1-4 near stair #2	12-6-12	OK
2-1	12-6-12	OK
2-2 near rm 201	12-6-12	OK
2-3	12-6-12	RECHARGE
2-4	12-6-12	OK
2-5	12-6-12	OK
B-1 sub-basement	12-6-12	OK
B-2 sub-basement	12-6-12	OK
B-3 sub-basement	12-6-12	OK
B-4 sub-basement	12-6-12	OK
B-5 sub-basement	12-6-12	OK

Richardson/Johnson

D. Richardson/Johnson #53
 Fire Compliance Officer/Asst Patrol Officer

[Signature]
 Chief of Police

1-3-13
 Date

1-3-13
 Date





Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: February 6, 2013 1030 hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	1-3-13	OK
1-2 near stair #1	1-3-13	OK
1-3 near exit door	1-3-13	OK
1-4 near stair #2	1-3-13	OK
2-1	1-3-13	OK
2-2 near rm 201	1-3-13	OK
2-3	1-3-13	OK
2-4	1-3-13	OK
2-5	1-3-13	OK
B-1 rm 145	1-3-13	OK
B-2 145 mechanical	1-3-13	OK
B-3 145 mechanical	1-3-13	OK
B-4 145 mechanical	1-3-13	OK
B-5 145 mechanical	1-3-13	OK

Richardson

Fire Compliance Officer/Asst Patrol Officer

Chief of Police

2-6-13
Date
2-28-13
Date



Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: March 4, 2013 1922

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	2-6-13	OK
1-2 near stair #1	2-6-13	Recharge
1-3 near exit door	2-6-13	OK
1-4 near stair #2	2-6-13	OK
2-1	2-6-13	OK
2-2 near rm 201	2-6-13	OK
2-3	2-6-13	OK
2-4	2-6-13	OK
2-5	2-6-13	OK
B-1 rm 145	2-6-13	OK
B-2 145 mechanical	2-6-13	OK
B-3 145 mechanical	2-6-13	OK
B-4 145 mechanical	2-6-13	OK
B-5 145 mechanical	2-6-13	OK
1-5 inside lounge	2-6-13	Tag required

P/O Richardson

Dolores Richardson

Fire Compliance Officer/Asst Patrol Officer

[Signature]
Dolores W. Richardson

Chief of Police

3.4.13

Date

3-4-13

Date



Cheyney State University of Pennsylvania
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: April 10, 2013 1340

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	3-4-13	tag required
1-2 near stair #1	3-4-13	Tag required
1-3 near exit door	3-4-13	Tag required
1-4 near stair #2	3-4-13	Tag required
2-1	3-4-13	OK
2-2 near rm 201	3-4-13	OK
2-3	3-4-13	OK
2-4	3-4-13	OK
2-5	3-4-13	OK
B-1 rm 145	3-4-13	OK
B-2 145 mechanical	3-4-13	OK
B-3 145 mechanical	3-4-13	OK
B-4 145 mechanical	3-4-13	OK
B-5 145 mechanical	3-4-13	OK
1-5 inside lounge	3-4-13	Tag required

P/O Richardson P/O Miles

 Fire Compliance Officer/Asst Patrol Officer

4.10.13
 Date

Chief of Police

4-10-13
 Date



Cheyney State University of Pennsylvania
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: May 15, 2013 1000 hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	4-10-13	tag required
1-2 near stair #1	4-10-13	Tag required
1-3 near exit door	4-10-13	Tag required
1-4 near stair #2	4-10-13	Tag required
2-1	4-10-13	OK
2-2 near rm 201	4-10-13	OK
2-3	4-10-13	OK
2-4	4-10-13	OK
2-5	4-10-13	OK
B-1 rm 145	4-10-13	OK
B-2 145 mechanical	4-10-13	OK
B-3 145 mechanical	4-10-13	OK
B-4 145 mechanical	4-10-13	OK
B-5 145 mechanical	4-10-13	OK
1-5 inside lounge	4-10-13	Tag required

P/O Richardson P/O Miles

Dalores Richardson

Fire Compliance Officer/Asst Patrol Officer

Lawrence W. Richards

Chief of Police

5.15.13

Date

5-15-13

Date



Cheyney State University of Pennsylvania
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: June 3, 2013 0955 hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	5-6-13	Tag required
1-2 near stair #1	5-6-13	Tag required
1-3 near exit door	5-6-13	Tag required
1-4 near stair #2	5-6-13	Tag required
2-1	5-6-13	OK
2-2 near rm 201	5-6-13	OK
2-3	5-6-13	OK
2-4	5-6-13	OK
2-5	5-6-13	OK
B-1 rm 145	5-6-13	OK
B-2 145 mechanical	5-6-13	OK
B-3 145 mechanical	5-6-13	OK
B-4 145 mechanical	5-6-13	OK
B-5 145 mechanical	5-6-13	OK
1-5 inside lounge	5-6-13	Tag required

P/O Richardson P/O Miles

Fire Compliance Officer/Asst Patrol Officer

Chief of Police

6-3-13
 Date

7-8-13
 Date



Cheyney State University of Pennsylvania
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: 7-6-2013 1203 hrs.

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	6-3-13	Tag required
1-2 near stair #1	6-3-13	Tag required
1-3 near exit door	6-3-13	Tag required
1-4 near stair #2	6-3-13	Tag required
2-1	6-3-13	OK
2-2 near rm 201	6-3-13	OK
2-3	6-3-13	OK
2-4	6-3-13	OK
2-5	6-3-13	OK
B-1 145 mechanical	6-3-13	OK
B-2 145 "	6-3-13	OK
B-3 145 "	6-3-13	OK
B-4 145 "	6-3-13	OK
B-5 145 "	6-3-13	OK
1-5 inside lounge	6-3-13	Tag required

P/O Richardson P/O Miles

Richardson

Fire Compliance Officer/Ast Patrol Officer

J. A. [Signature]

Chief of Police

7-6-13

Date

9-4-13

Date



Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Duckery Science

Date/Time of Inspection: 8/31/2013

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	8/31/13	
1-2 near stair #1	8/31/13	
1-3 near exit door	8/31/13	
1-4 near stair #2	8/31/13	
2-1	8/31/13	
2-2 near rm 201	8/31/13	
2-3	8/31/13	
2-4	8/31/13	
2-5	8/31/13	
B-1 145 mechanical	8/30/13	
B-2 145 "	8/30/13	
B-3 145 "	8/30/13	
B-4 145 "	8/31/13	
B-5 145 "	8/31/13	
1-5 inside lounge	8/31/13	NO HAND TAG

Annal Tesey
Fire Compliance Officer/Asst Patrol Officer

Lawrence W. Richard
Chief of Police

8/31/2013
Date

9/10/13
Date




Cheyney State University of Pennsylvania
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT


Building: Duckery Science

Date/Time of Inspection: 09/30/13, 0830 hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1 near elevator	8/31/13	OK
1-2 near stair #1	8/31/13	OK
1-3 near exit door	NO TAG	OK - Need Tag
1-4 near stair #2	8/31/13	OK - need new tag
2-1	OLD TAG	OK - Need New TAG
2-2 near rm 201	8/31/13	OK
2-3	8/31/13	OK
2-4	8/31/13	OK
2-5	8/31/13	OK
B-1 145 mechanical	8/31/13	OK
B-2 145 "	8/31/13	OK
B-3 145 "	8/31/13	OK
B-4 145 "	8/31/13	OK
B-5 145 "	8/31/13	OK
1-5 inside lounge	NO TAG	OK - Need Tag

 #11
Fire Compliance Officer/Asst Patrol Officer

9/30/13
Date


Chief of Police Lawrence W. Richards

9/30/13
Date