





2013

Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Truth Hall Page 1 of 2

Date/Time of Inspection: 01/05/2013

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	12-12	
1-2	12-12	
1-3	12-12	
1-4	12-12	
1-5	12-12	
2-1	12-12	
2-2	12-12	
2-3	12-12	
2-4	12-12	
2-5	12-12	
3-1	12-12	
3-2	12-12	
3-3	12-12	
3-4	12-12	
3-5	12-12	
4-1	12-12	
4-2	12-12	
4-3	12-12	
4-4	12-12	
4-5	12-12	

Fire Compliance Officer/Asst Patrol Officer

James Keith

01/05/2013

Chief of Police

Date

1/5/13



Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: TRUTH HALL

Date/Time of Inspection: February 4, 2013 0900hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	1-3-2013	OK
1-1	1-3-2013	OK
1-2	1-3-2013	OK
1-3	1-3-2013	OK
1-4	1-3-2013	OK
1-5	1-3-2013	OK
RA OFFICE	12-3-2012	OK
2-1	1-3-2013	OK
2-2	1-3-2013	OK
2-3	1-3-2013	OK
2-4	1-3-2013	OK
2-5	1-3-2013	OK
3-1	1-3-2013	OK
3-2	1-3-2013	OK
3-3	1-3-2013	OK
3-4	1-3-2013	OK
3-5	1-3-2013	OK
4-1	1-3-2013	OK
4-2	1-3-2013	OK
4-3	1-3-2013	missing
4-4	1-3-2013	OK
4-5	1-3-2013	OK
LOUNGE AREA	1-3-2013	OK

D. Richardson

*Dalores Richardson*  
 Fire Compliance Officer/Asst Patrol Officer

*D. Richard*  
 Chief of Police

2.4.13

Date

2.28.13

Date





Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

Building: TRUTH HALL

Date/Time of Inspection: March 8, 2013 0900hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	2-4-2013	OK
1-1	2-4-2013	OK
1-2	2-4-2013	OK
1-3	2-4-2013	OK
1-4	2-4-2013	OK
1-5	2-4-2013	OK
RA OFFICE	2-4-2013	OK
2-1	2-4-2013	OK
2-2	2-4-2013	OK
2-3	2-4-2013	OK
2-4	2-4-2013	OK
2-5	2-4-2013	OK
3-1	2-4-2013	OK
3-2	2-4-2013	OK
3-3	2-4-2013	OK
3-4	2-4-2013	OK
3-5	2-4-2013	OK
4-1	2-4-2013	OK
4-2	2-4-2013	OK
4-3	2-4-2013	missing
4-4	2-4-2013	OK
4-5	2-4-2013	OK
LOUNGE AREA	2-4-2013	OK

P/O Richardson P/O Miles

*Dalores Richardson*  
 Fire Compliance Officer/Asst Patrol Officer

4-8-13  
 Date

\_\_\_\_\_  
 Chief of Police

\_\_\_\_\_  
 Date





Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

Building: TRUTH HALL

Date/Time of Inspection: April 8, 2013 0845hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	3-8-2013	OK
1-1	3-8-2013	OK
1-2	3-8-2013	OK
1-3	3-8-2013	OK
1-4	3-8-2013	OK
1-5	3-8-2013	OK
RA OFFICE	3-8-2013	OK
2-1	3-8-2013	OK
2-2	3-8-2013	OK
2-3	3-8-2013	OK
2-4	3-8-2013	OK
2-5	3-8-2013	OK
3-1	3-8-2013	OK
3-2	3-8-2013	OK
3-3	3-8-2013	OK
3-4	3-8-2013	OK
3-5	3-8-2013	OK
4-1	3-8-2013	OK
4-2	3-8-2013	OK
4-3	3-8-2013	OK
4-4	3-8-2013	OK
4-5	3-8-2013	OK
LOUNGE AREA	3-8-2013	OK

P/O Richardson P/O Miles~

*Richardson*  
 Fire Compliance Officer/Asst Patrol Officer

4-8-13  
 Date

\_\_\_\_\_  
 Chief of Police

\_\_\_\_\_  
 Date







Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

**B**uilding: TRUTH HALL

**D**ate/Time of Inspection: May 3, 2013 1000hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	4-8-2013	OK
1-1	4-8-2013	OK
1-2	4-8-2013	OK
1-3	4-8-2013	OK
1-4	4-8-2013	OK
1-5	4-8-2013	OK
RA OFFICE	4-8-2013	OK
2-1	4-8-2013	OK
2-2	4-8-2013	OK
2-3	4-8-2013	missing
2-4	4-8-2013	OK
2-5	4-8-2013	OK
3-1	4-8-2013	OK
3-2	4-8-2013	missing
3-3	4-8-2013	OK
3-4	4-8-2013	OK
3-5	4-8-2013	OK
4-1	4-8-2013	Recharge
4-2	4-8-2013	OK
4-3	4-8-2013	OK
4-4	4-8-2013	OK
4-5	4-8-2013	OK
LOUNGE AREA	4-8-2013	OK

P/O Wilson

\_\_\_\_\_  
 Fire Compliance Officer/Asst Patrol Officer

\_\_\_\_\_  
 Date

\_\_\_\_\_  
 Chief of Police

\_\_\_\_\_  
 Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

TRUTH HALL: CONT

Building: \_\_\_\_\_

Date/Time of Inspection: Fire Extinguisher Number	Date of Last Inspection	Comments
5-1	4-8-2013	OK
5-2	"	OK
5-3	"	OK
5-4	"	OK
5-5 near rm 505	"	Tag Required
6-1	"	OK
6-2	"	OK
6-3	"	Recharge
6-4	"	Recharge
6-5	"	Recharge
B-1 laundry rm	"	missing
B-2	"	missing
B-5	"	missing
B-3		OK

P/O Wilson

\_\_\_\_\_  
Fire Compliance Officer/Asst Patrol Officer

\_\_\_\_\_  
Date

\_\_\_\_\_  
Chief of Police

\_\_\_\_\_  
Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

Building: TRUTH HALL

Date/Time of Inspection: June 3, 2013 1030 hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	5-3-2013	OK
1-1	5-3-2013	OK
1-2	5-3-2013	OK
1-3	5-3-2013	OK
1-4	5-3-2013	OK
1-5	5-3-2013	OK
RA OFFICE	5-3-2013	5 extinguishers 2 ok 3 recharge
2-1	5-3-2013	OK
2-2	5-3-2013	OK
2-3	5-3-2013	Missing
2-4	5-3-2013	OK
2-5	5-3-2013	OK
3-1	5-3-2013	OK
3-2	5-3-2013	Recharge
3-3	5-3-2013	OK
3-4	5-3-2013	OK
3-5	5-3-2013	OK
4-1	5-3-2013	Missing
4-2	5-3-2013	OK
4-3	5-3-2013	Missing
4-4	5-3-2013	Missing
4-5	5-3-2013	OK
LOUNGE AREA	5-3-2013	OK

P/O Richardson/Miles

*Salvatore Richardson*

Fire Compliance Officer/Asst Patrol Officer

*J. Whick*

Chief of Police

6-3-13

Date

7-8-13

Date





APRIL

Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: TRUTH HALL

Date/Time of Inspection: 7 29 2013 @ 19:45 - 20:20  
March 8, 2013 0900hrs

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	7.29.13	OK 77
1-1	7.8.13	OK 77
1-2	7.8.13	OK 77
1-3	7.8.13	OK 77
1-4	7.8.13	OK 77
1-5	—	OK 77
RA OFFICE	5.3.13	missing 77
2-1	7.8.13	OK 77
2-2	7.8.13	OK 77
2-3	—	OK 77
2-4	7.8.13	missing 77
2-5	7.8.13	OK 77
3-1	7.8.13	OK 77
3-2	—	OK 77
3-3	unk	missing 77
3-4	unk	OK 77 needs Tag
3-5	7.8.13	OK 77 needs Tag
4-1	—	OK 77
4-2	7.8.13	missing 77
4-3	—	OK 77
4-4	—	missing 77
4-5	7.8.13	missing 77
LOUNGE AREA	7.8.13	OK 77

P/O Richardson P/O Miles CALVIN WILSON

7.29.13 monday

Fire Compliance Officer/Asst Patrol Officer

Chief of Police

Date

9-4-13

Date



Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

TRUTH HALL: CONT

Building: \_\_\_\_\_

Date/Time of Inspection:	Fire Extinguisher Number	Date of Last Inspection	Comments
	5-1	[REDACTED]	[REDACTED]
	5-2	[REDACTED]	MISSING 77
	5-3	[REDACTED]	MISSING 77
	5-4	[REDACTED]	MISSING 77
	5-5 near rm 505	unk	MISSING 77
	6-1	7.8.13	Tag need OK needs tag 77
	6-2	7.8.13	needs charged 77
	6-3	7.8.13	OK 77
	6-4	[REDACTED]	recharge need charged 77
	6-5	7.8.13	recharge missing - 77
	B-1 laundry rm	[REDACTED]	recharge need charged 77
	B-2 1229a	[REDACTED]	MISSING - 77
	B-5 missing	[REDACTED]	OK
	B-3 5-13-13	[REDACTED]	MISSING - 77
			OK - 77

P/O Richardson / P/O Miles

Fire Compliance Officer/Asst Patrol Officer

*[Signature]*

Chief of Police

Date

9-4-13

Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: TRUTH HALL

Date/Time of Inspection: August 23, 2013

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	7/8/2013	NO GLASS
1-1	7/29/2013	NO CASE
1-2	7/29/2013	NO GLASS
1-3	7/29/2013	NO GLASS LOCK
1-4	7/29/2013	NO GLASS
1-5	7/29/2013	GOOD
RA OFFICE	7/29/2013	NO CASE
2-1	7/29/2013	GOOD
2-2	7/29/2013	GOOD
2-3	12/2012	NO GLASS
2-4	7/29/2013	GOOD
2-5	7/29/2013	NO GLASS
3-1	6/3/2013	NO CASE
3-2	7/29/2013	GOOD
3-3	12/2012	
3-4	12/2012	NO GLASS
3-5	7/29/13	NO CASE
4-1	NO TAG	NO TAG/GLASS
4-2	7/29/2013	NO GLASS
4-3	NO TAG	NO GLASS
4-4	12/2012	NO GLASS
4-5	7/29/2013	GOOD
LOUNGE AREA	7/29/2013	

*Dylen Chapman*  
Fire Compliance Officer/Assl Patrol Officer

August 23, 2013  
Date

*Lawrence W. Richards*  
Chief of Police

9/16/13  
Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

TRUTH HALL: CONT

Building: \_\_\_\_\_

Date/Time of Inspection: Fire Extinguisher Number	Date of Last Inspection	Comments
5-1	December 2012	NO glass
5-2	December 2012	NO glass
5-3	June 3, 2013	NO glass
5-4	January 7, 2013	NO glass
5-5 near rm 505	NO TAG	NO glass
6-1	January 2012	NO glass
6-2	July 29, 2013	NO glass
6-3	December 2012	NO glass
6-4	November 2012	NO glass
6-5	December 2012	NO glass
B-1 laundry rm	Empty	
B-2	Empty	
B-5	Empty	
B-3	Empty	

\_\_\_\_\_  
Delex Chapman August 23, 2013  
Fire Compliance Officer/Asst Patrol Officer Date

\_\_\_\_\_  
Lawrence W. Richards 9/16/13  
Chief of Police Date





409

Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division


ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: TRUTH HALL

Date/Time of Inspection: 9/12/13

Handwritten initials

Fire Extinguisher Number	Date of Last Inspection	Comments
M-1 near rear exit	8-6-13	Top glass missing
1-1	8-29-13	OIS
1-2	8-29-13	OIS
1-3	8-29-13	OIS
1-4	8-29-13	OIS
1-5	New card	OIS
RA OFFICE	8-29-13	OIS
2-1	8-29-13	OIS
2-2	8-29-13	OIS
2-3	New card	OIS
2-4	8-29-13	OIS
2-5	8-29-13	OIS
3-1	8-29-13	OIS
3-2	New card	OIS
3-3	New card	OIS
3-4	<del>6-13</del> 8-3-13	front glass missing
3-5	8-29-13	front glass missing
4-1	NO card	NO card & glass broken
4-2	8-29-13	OIS
4-3	NO card	NO card
4-4	New card	OIS
4-5	8-29-13	OIS
LOUNGE AREA	8-29-13	OIS

  
Fire Compliance Officer / Asst Patrol Officer

9/12/13  
Date

  
Chief of Police

9/12/13  
Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

TRUTH HALL: CONT

Building: TRUTH Hall

Date/Time of Inspection: Fire Extinguisher Number	Date of Last Inspection	Comments
5-1	New card	Front glass missing
5-2	New cover	OK
5-3	8-3-13	OK
5-4	8-2-13	OK
5-5 near rm 505	No card	Card missing
6-1	New cover	Missing front glass
6-2	8-29-13	Missing front glass
6-3	New card	Front Glass <del>broken</del> MISSING
6-4	New card	Front Glass missing
6-5	New card	Front glass missing
B-1 laundry rm	New card	OK
B-2		unable to locate
B-5	Extinguisher missing	MISSING
B-3		

[Signature]  
Fire Compliance Officer/Asst Patrol Officer

9/12/13  
Date

[Signature]  
Chief of Police Lawrence W. Richards

9/12/13  
Date