



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

Building: Tubman Hall

Date/Time of Inspection: 8/01/2012

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	7-12	
1-2	7-12	Needs new tag
2-1	7-12	
2-2	7-12	
3-1	7-12	
3-2	7-12	
4-1	7-12	
4-2	7-12	
5-1	7-12	
5-2	7-12	
6-1	7-12	
6-2	7-12	Missing
7-1	7-12	
7-2	7-12	No tag
B-1	7-12	
B-2	7-12	
B-3	7-12	

James Keith

8/01/2012

\_\_\_\_\_  
Fire Compliance Officer/Asst Patrol Officer

\_\_\_\_\_  
Date

*L. W. Richards*

*8-1-12*

Chief of Police

\_\_\_\_\_  
Date

*8-1-12*



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT


Building: Tubman Hall

Date/Time of Inspection: 7/02/2012


Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	6-12	
1-2	6-12	Needs new tag
2-1	6-12	
2-2	6-12	
3-1	6-12	
3-2	6-12	
4-1	6-12	
4-2	6-12	
5-1	6-12	
5-2	6-12	
6-1	6-12	
6-2	6-12	Missing
7-1	6-12	
7-2	6-12	No tag
B-1	6-12	
B-2	6-12	
B-3	6-12	


James Keith

7/02/2012

  
\_\_\_\_\_  
Fire Compliance Officer/Asst Patrol Officer

\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Chief of Police

  
\_\_\_\_\_  
Date





Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

Building: Tubman Hall

Date/Time of Inspection: 6-12

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	5-12	
1-2	5-12	Needs new tag
2-1	5-12	
2-2	5-12	
3-1	5-12	
3-2	5-12	
4-1	5-12	
4-2	5-12	
5-1	5-12	
5-2	5-12	
6-1	5-12	
6-2	5-12	Missing
7-1	5-12	
7-2	5-12	No tag
B-1	5-12	
B-2	5-12	
B-3	5-12	

James Keith

*[Signature]*  
Fire Compliance Officer/Asst Patrol Officer

*J. W. Richards*  
Chief of Police

6/12 *6-3-12*  
Date

*6-3-12*  
Date




Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Tubman Hall

Date/Time of Inspection: 5-12

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	4-12	
1-2	4-12	
2-1	4-12	
2-2	4-12	
3-1	4-12	
3-2	4-12	
4-1	4-12	
4-2	4-12	
5-1	4-12	
5-2	4-12	
6-1	4-12	
6-2	4-12	
7-1	4-12	
7-2	4-12	
B-1	4-12	
B-2	4-12	
B-3	4-12	

P. J. Herd 81  
 Fire Compliance Officer / Asst. Patrol Officer  
  
Lawrence W. Richards  
 Chief of Police

5-22-12  
 Date  
5-22-12  
 Date



CHEYNEY UNIVERSITY OF PENNSYLVANIA  
Office of Public Safety

ACADEMIC/ADMINISTRATIVE BUILDING FIRE EXTINGUISHER INSPECTION REPORT

Building: TUBMAN HALL  
Date/Time of Inspection: 4-4-12 1010hrs

\* (7)  
\* (6)  
\*  
\*

FIRE EXTINGUISHER NUMBER	DATE OF LAST INSPECTION	COMMENTS
7-2	MISSING	→
7-1	4-12	OK
6-1	4-12	Low
6-2	MISSING	→
5-2	4-12	OK
5-1	New TAG	OK
4-1	4-12	OK
4-2	4-12	Low
3-2	4-12	OK
3-1	4-12	OK
2-1	4-12	OK
2-2	4-12	OK
1-1	4-12	OK → Need another TAG
1-2	4-12	OK
R/A Desk	9-11	OK
B-1	4-12	OK
B-4	4-12	OK
B-3	4-12	OK
B-2	4-12	OK

[Signature] 9960 4-4-12  
Fire Compliance Officer/Assisting Patrol Officer and Badge Number Date

Coordinator, Fire Safety Education & Awareness Date  
[Signature] 4-4-12  
Director of Public Safety Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Tubman Hall

Date/Time of Inspection: 04/2012

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	3-12	
1-2	3-12	
2-1	3-12	
2-2	3-12	
3-1	3-12	
3-2	3-12	
4-1	3-12	
4-2	3-12	missing
5-1	3-12	
5-2	3-12	
6-1	3-12	
6-2	3-12	
7-1	3-12	
7-2	3-12	

P.O. J. Keith 81  
Fire Compliance Officer/Asst Patrol Officer

L. W. Richards  
Chief of Police

4-2-12  
Date

4-2-12  
Date



Cheyney State University of Pennsylvania  
 Cheyney University Police Department – Fire Safety Division

**ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT**

Building: Tubman hall

Date/Time of Inspection: \_\_ March 2, 2012 2012

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	2-2-12	OK need tag
1-2	2-2-12	OK
2-1	2-2-12	OK
2-2	2-2-12	OK
3-1	2-2-12	OK
3-2	2-2-12	OK
4-1	2-2-12	OK
4-2	2-2-12	OK
5-1	New Tag	OK
5-2	2-2-12	OK
6-1	2-2-12	RECHARGE
6-2	Missing	Missing
7-1	2-2-12	OK
7-2	Missing	Missing
B-1	2-2-12	OK
B-2	2-2-12	OK
B-3	2-2-12	OK
B-4	2-2-12	OK

P/O Richardson

Fire Compliance Officer/Asst Patrol Officer

3-2-12

Date

Chief of Police

Date





Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Tubman Hall

Date/Time of Inspection: 02/02/12

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	11-11	
1-2	11-11	
2-1	11-11	
2-2	11-11	
3-1	11-11	
3-2	11-11	
4-1	11-11	
4-2	11-11	
5-1	11-11	
5-2	11-11	
6-1	11-11	
6-2	11-11	
7-1	11-11	
7-2	11-11	

James Keith 81  
Fire Compliance Officer/Asst Patrol Officer  
L. W. Richards  
Chief of Police

02-02-12  
Date  
02-02-12  
Date



Cheyney State University of Pennsylvania  
Cheyney University Police Department – Fire Safety Division

ACADEMIC/ADMISTRATIVE BUILDING FIRE EXTINGUISHER REPORT

Building: Tubman Hall

Date/Time of Inspection: 01/07/2012

Fire Extinguisher Number	Date of Last Inspection	Comments
1-1	11-11	
1-2	11-11	
2-1	11-11	
2-2	11-11	
3-1	11-11	
3-2	11-11	
4-1	11-11	
4-2	11-11	Empty needs to be filled
5-1	11-11	
5-2	11-11	
6-1	11-11	
6-2	11-11	
7-1	11-11	
7-2	11-11	

S.O Boanes \_\_\_\_\_  
Officer \_\_\_\_\_  
*L.W. Richards*  
Chief of Police

Fire Compliance Officer/Asst Patrol  
\_\_\_\_\_  
*1-9-12*  
Date